

Type Approval Certificate Extension

This is to certify that Certificate No. 01/00171 for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER	CMP PRODUCTS
PLACE OF PRODUCTION	Glasshouse Street St. Peters Newcastle-Upon-Tyne, NE6 1BE United Kingdom (UK)
DESCRIPTION	Cable glands for non-hazardous areas
TYPES	BW Indoor use BWL Indoor use A2 Indoor/outdoor use CW Indoor/outdoor use EIW Indoor/outdoor use CX/Z Indoor/outdoor use EIX/Z Indoor/outdoor use E2W Indoor/outdoor use C2KX Jacketed cable B2KX Non-jacket cable, Dry locations MCR Indoor/outdoor use MCRA Indoor/outdoor use A2P (V-TEC) Plastic gland
APPLICATION	Marine, offshore and Industrial use
STANDARD	BS 6121: 1989
Certificate No.	01/00171(E1)
Issue Date	8 November 2007
Expiry Date	8 December 2011
Sheet	1 of 2

M. A. Ruffaie

M.H.A. Ruffaie
London Design Support Services
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS

**OTHER
CONDITIONS**

The equipment should not be used for the protection of cables passing through watertight, fire insulated or gas tight bulkheads or decks separating dangerous zones or spaces from non-dangerous zones or spaces.

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No. 01/00171(E1) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 01/00171 to which this extension should be attached.

Certificate No. 01/00171(E1)
Issue Date 8 November 2007
Expiry Date 8 December 2011
Sheet 2 of 2



M.H.A. Rufaie
London Design Support Services
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS



Lloyd's Register EMEA (London Office)

LONDON DESIGN SUPPORT SERVICES

71 Fenchurch Street, London, EC3M 4BS

Telephone 020 7709 9166 Fax 020 7488 4796

Email tad@lr.org

Page 1 of 1
Document number 01/00171(E1)
Issue number 1

DESIGN APPRAISAL DOCUMENT

Date 8 November 2007	Quote this reference on all future communications LDSS/PAS/TA/W01406344/MHR/O- 86515
-------------------------	---

LLOYD'S REGISTER TYPE APPROVAL SYSTEM, 2002.

Issued to: CMP PRODUCTS

for: CABLE GLANDS FOR NON-HAZARDOUS AREAS

TYPE APPROVAL CERTIFICATE No. 01/00171(E1)

The undernoted documents have been reviewed for compliance with the requirements of the Lloyd's Register Type Approval System, 2002 and this Design Appraisal Document forms part of the Certificate.

ADDITIONAL APPROVAL DOCUMENTATION

Request form	05.03.2007
CMP Letter	Undated
CMP catalogue (TPC 2007)	09.2007

TEST REPORTS

BVQi Certificate No. 20523	24.05.2006
----------------------------	------------

Also all the documentation listed on Design Appraisal Document associated with Type Approval Certificate No. 01/00171

Supplementary Type Approval Terms and Conditions

Type Approval certifies that a representative sample of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein. It does not mean or imply approval for any other use, nor approval of any product(s) designed or manufactured otherwise than in strict conformity with the said representative sample.

Type Approval is based on the understanding that the manufacturer's recommendations and instructions and any relevant requirements of the Rules and Regulations are complied with.

Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations.

Lloyd's Register EMEA reserves the right to cancel or withdraw this Type Approval Certificate in accordance with the Lloyd's Register Type Approval System Procedure.

M.H.A. RUF AIE

Lead Specialist

Product Approval / London Design Support Services

Tel: +44 (0) 20 7423 1849 (Direct line)

Email: product-approval@lr.org

Web: www.lr.org

Part 1B

Subject: Electrical Equipment (Not Environmentally Tested)

Product: Cables Accessories (Part 1B)

Description of Product		Description of Product		Cert. No.
Producer/Licence No.	Type	Details of Approval	Application	
CMP PRODUCTS, Glasshouse Street, St. Peters, Newcastle-Upon-Tyne, NE6 1BE, United Kingdom (UK).	Cable glands for non-hazardous areas		Marine, offshore and Industrial use	Expires: 08 December 2011 BS 6121: 1989 The equipment should not be used for the protection of cables passing through watertight, fire insulated or gas tight bulkheads or decks separating dangerous zones or spaces from non-dangerous zones or spaces.
	BW	Indoor use		
	BWL	Indoor use		
	A2	Indoor/outdoor use		
	CW	Indoor/outdoor use		
	E1W	Indoor/outdoor use		
	CX/Z	Indoor/outdoor use		
	E1X/Z	Indoor/outdoor use		
	E2W	Indoor/outdoor use		
	C2KX	Jacketed cable		
	B2KX	Non-jacket cable, Dry locations		
	AZP (V-TEC)	Plastic gland		
	MCR	Indoor/outdoor use		
MCRA	Indoor/outdoor use			

- 8 NOV 2007
 MH